

FIRE SAFETY CERTIFICATE

Dated: 27 MAR 2024

No. APSP/1003/FIRESAFE/2024-25

Certified that the ARMY PUBLIC SCHOOL, GHORPADI (name of the building) or premises at GHORPADI (address) comprised of PUNE, MAHARASHTRA basement(s) and TWO

(upper floors) owned/ occupied by ARMY PUBLIC SCHOOL, GHORPADI (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 27TH MAR 2024 (date of inspection) in the presence of XII (name and addresses of the Manager/ Secretary or his representative) and that the building/ premises is fit for occupancy upto classes ONE (X/ XII) With effect from 27 MARCH 2024 for a period of ONE year in accordance with rule and subject to compliance of specific conditions as appended:-

1. Each floor to have Fire Exits clearly marked with CO2 trolleys placed.
2. Fire Alarm Switches to be placed near Fire Exits.
3. Adequate Firebells with OMTs, BUs & Sumps.
4. Each floor to have 30 m long non-pneumatic pipe storage cabinets with heat & smoke sensors.

Issued on 27 MAR 2024 (date of issue) at PUNE (place) by

*Strike out whichever is not applicable.

Signature with Seal: [Signature] ले कर्नल/कर्नल
Lt Col / Col
अधि सल्लाहकार (कमान)
Name: SAURAV PATTI Fire Advisor (Command)
Designation: LT COL, FIRE ADVISOR मुख्यालय दक्षिण कमान
Name & Address of Department/ Office: H.Q. SOUTHERN
COMD (COL)

To

ARMY PUBLIC SCHOOL, GHORPADI,
PUNE - 411001
(Name & Address of the Institution)

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled an annulled due to

(reasons to be recorded).

(Name and designation of the authorized signatory)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.